

REAL ESTATE AND CONSTRUCTION DIVISION WEEKLY REPORT FOR PERIOD ENDING 23 JULY 1986

1. Progress Report Tasks Assigned by the DCI/DDCI:

No tasks assigned during this reporting period.

2. Items or Events of Major Interest That Have Occurred During the Preceding Week:

25X1

25X1

25X1

25X1

25X1

25X1

25X1

- Asbestos Briefing at Ames Building On 17 July 1986, as a result of a follow-up inspection of the asbestos situation at Ames Building, an impromptu briefing was given to Office of Personnel (OP) employees by Safety Division, Office of Medical Services. Estate and Construction Division, OL, provided input regarding the efforts underway to temporarily relocate these employees, and the involvement of the General Services Administration (GSA). The OP employees are concerned about existing and/or potential danger from asbestos exposure, but they were informed that airborne asbestos exposure levels in their working area are in compliance with Occupational Safety and Health Administration standards. because the space above the ceiling is used as an air plenum, removal of the asbestos is recommended by our Safety Division and The removal is also required by GSA as a condition for the renewal of the Ames Building lease. Green).
- b. Lease Action On the advice of Safety Staff,
 Office of Medical Services, renovations were
 halted Decause of the presence of asbestos. Pending resolution of
 the asbestos problem in the action has been taken,
 effective 10 July 1986, to reduce the rent payment consistent with
 the amount of space available. For performance.

| ڼ | d. Project - Office of Security is |
|---------------|--|
| 25 X 1 | d. Project - Office of Security is |
| 25 X 1 | scheduled to move on 25-26 July, 1986. |
| 1 | Office of Information Technology is scheduled to have the |
| | installation of their black lines, KY-71 phones, and Wangs completed |
| 25 X 1 | on 25 July. |
| | |
| 25 X 1 | |
| | |
| | |

SECRET

SUBJECT: Real Estate and Construction Division Weekly Report for Period Ending 23 July 1986

| 25X1 | |
|--------------------------------|---|
| | Office of Rogistics has moved the |
| 25X1 25X1 25X1 () | q. Polygraph Division Renovation, Third Floor The Polygraph Division has moved into the third floor and is operational. There are two items which continue to give problems: 1. The Office of Information Technology has not accepted the earth ground for the communications equipment room, so efforts continue to bring the resistance down. |
| 25 X 1 25 X 1 | The air-conditioning unit for the guard personnel did not operate properly this past weekend while the building system was off. This caused temperatures to reach ninety degrees Fahrenheit at the guard post. The Architect-Engineer has been to the site to propose a solution. Significant Events Anticipated During the Coming Week: |
| 25 X 1 | None. |
| | |

2